



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A0521

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Beaver River 3

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 01/06/2017
Reported: 01/16/2017

Analytical Testing Parameters

Table with 2 columns: Client Sample ID: 56 A, Sample Matrix: Drinking Water, Lab Sample ID: J7A0521-01; Collected By: RF-Client, Collection Date: 12/30/2016 8:14

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Method: EPA 200.8/EPA 200.8, Rv 5.4. Lead: 0.0471, 0.015 AL, 0.000500, mg/L, CC, 01/10/17 1757, 01/11/17 1807, NY

Table with 2 columns: Client Sample ID: 47 A, Sample Matrix: Drinking Water, Lab Sample ID: J7A0521-02; Collected By: RF-Client, Collection Date: 12/30/2016 8:10

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Method: EPA 200.8/EPA 200.8, Rv 5.4. Lead: 0.0999, 0.015 AL, 0.000500, mg/L, CC, 01/11/17 1342, 01/11/17 1807, NY

Table with 2 columns: Client Sample ID: 244 A, Sample Matrix: Drinking Water, Lab Sample ID: J7A0521-03; Collected By: RF-Client, Collection Date: 12/30/2016 8:13

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Method: EPA 200.8/EPA 200.8, Rv 5.4. Lead: 0.0206, 0.015 AL, 0.000500, mg/L, CC, 01/11/17 1342, 01/11/17 1807, NY

Table with 2 columns: Client Sample ID: 148, Sample Matrix: Drinking Water, Lab Sample ID: J7A0521-04; Collected By: RF-Client, Collection Date: 12/30/2016 8:18

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Method: EPA 200.8/EPA 200.8, Rv 5.4. Lead: 0.0471, 0.015 AL, 0.000500, mg/L, CC, 01/11/17 1342, 01/11/17 1807, NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7A0521

<b>Client Sample ID:</b> 54	<b>Collected By:</b> RF-Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 12/30/2016 8:12
<b>Lab Sample ID:</b> J7A0521-05	

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Lab
<b>Method: EPA 200.8/EPA 200.8, Rv 5.4</b>								
Lead	0.0587	0.015 AL	0.000500	mg/L	CC	01/11/17 1342	01/11/17 1807	NY

**Laboratory**  
 NY: Microbac Laboratories, Inc., New York Division

**Definitions**  
 AL: Action Level  
 CC: Result fails applicable NYS drinking water standards.  
 RL: Reporting Limit

**Project Requested Certification(s)**  
 Microbac Laboratories, Inc., New York Division  
 NY Lab ID No.: 10795  
 New York State Department of Health

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

*Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

**Reviewed and Approved By:**

Andrew Canale For Michael Fifield  
 Division Manager  
 michael.fifield@microbac.com  
 01/16/2017 17:53

Phone: (607) 753-3403  
 Fax: (607) 753-3415  
 NY #10795, EPA #NY00895

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

Bayer Luce 3

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Familione-Herkimer, Onida BOCES		20104 NYS Route 3		Ice: YES NO		Coolers: YES NO	
Address: Watertown, NY 13601		Ray Filley		Sample Temp:		Cooler Seal: YES NO	
Phone: 315-779-7054		Lead Testing		Pickup: YES NO		Dropoff: C W	
Project: Lead Testing		Quote ID:		Accepted? YES NO		Container Material	
Rush TAT Bur. Days: 2-5 5-7 7-10		PO#: 200.8 Lead		Container size (in MI)		Preservative	
Release to DOH: Yes		Date Req.:		Number of Containers for Analysis Requested		Comments/Field Data	
Email Results: Yes		rfiley@boces.com / fhack@boces.com					
Fax Results: Yes							
Sample Information							
Description/Location	Date	Time	Initial	Matrix Type			
1 S6 A	12/30	8:14	RF				
2 47 A		8:10					
3 244 A		8:13					
4 148		8:18					
5 54		8:12					
6							
7							
8							
Sampled: Raymond Spivey				Signature: <i>[Signature]</i>			
Received: Ernest Spivey				Date/Time: 1/4/16 12:00			
Received:				Date/Time: 1/10/17 10:53			
Received:							
Received:							
Received:							



J7A0521

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and...